

Our Ref: CR/JC

9th January 2008

WRAS
Water Regulations Advisory Scheme

Permabond Engineering Adhesives Ltd.
Wessex Business Park,
Wessex Way,
Colden Common,
Hants
SO21 1WP

Dear Sir

**WATER REGULATIONS ADVISORY SCHEME
"ITEMS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY - BS 6920"**

We refer to your application for the material(s) described below to be approved arising from the results of the tests of effect on water quality that have been carried out on the product(s) so described, it has been decided that there is no objection to its/their use provided the source, nature and manufacturing processes of the ingredients and products are not changed. (See notes overleaf).

SEALANTS - SCREWED JOINTS - ANAEROBIC ADHESIVES 5520

Anaerobic adhesives grades, translucent liquids - A011 Red, A025 Orange, A113 Blue, A115 Orange, A118 Green, A126 Green, A130 Blue, A131 White, A134 Green, A136 Red, A140 Green, A1038 Yellow, A1040 Yellow, A1042 Blue, A1044 White, A1058 Off White, APP777 Green, F200 Brown, F201 Brown, F202 Brown, A1084 Yellow applied to brass coupling. All grades cured 24 hours at 23°C except A1058 cured 36 hours at 23°C. Cold water and hot water use up to 85°C.

Test Report: MA2827/W

0311503 PERMABOND ENGINEERING ADHESIVES LTD

An entry, as above, will accordingly be included in the Water Fittings and Materials Directory, Part Two, under the section headed, "Materials which have passed full tests of effect on water quality".

Your attention is drawn to the statement overleaf. Manufacturers or applicants may only quote in their sales literature terms which are used in this letter, namely that the product as listed, having passed the tests of effect on water quality, is suitable for use in contact with potable water and that a reference to the product will be included in the Materials section, Part Two, of the Water Fittings and Materials Directory: this may be abbreviated to "Water Regulations Advisory Scheme - Approved Product" or "WRAS - Approved Product". Approval of this product does not signify the approval of its mechanical or physical properties for any use.

The Technical Committee of the Scheme reserves the right to review approval. This product automatically becomes due for audit reassessment in November 2008.

Yours faithfully
H.E. Lewis
Hannah Lewis (Miss)
Materials Administrator
Water Regulations Advisory Scheme

Water Regulations Advisory Scheme
30 Park Close, First Floor Industrial Estate,
Osborne, Gosport, PO13 3JL, UK.
Tel: 01405 248554 Fax: 01405 249234
E-mail: info@wras.co.uk Website: www.wras.co.uk

WRAS 08
Approved Product 0311503
Approved Product 0311503
Approved Product 0311503

WRAS
Water Regulations Advisory Scheme

MATERIALS WHICH HAVE PASSED FULL TESTS OF EFFECT ON WATER QUALITY AND ARE USED IN THE MANUFACTURE OF WATER FITTINGS AND WATER INSTALLATIONS AND IN THEIR ASSEMBLY, CONNECTION, DISCONNECTION AND REPAIR.

The material or product referred to in this letter is suitable for contact with, and for the manufacture of components of water fittings for use in contact with water for domestic purposes. The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use. Certain products are approved in the full knowledge that for many plastic materials and natural and synthetic rubbers, variations in curing times and temperatures may have a significant effect on water quality. The right is reserved to require the testing of components made from any of these materials before listing those components if the scheme has any reason to believe that they differ from the materials originally tested and listed.

Entries in the Directory relating to components made from listed materials are included on the understanding that the components are made of precisely the same materials as the test samples without any modification and without the addition or substitution of any ingredients, and that, as applicable, the curing times and temperature shall be as nearly as possible those recommended by the manufacturers of the materials or products and used for the production of test samples.

In order to avoid their affecting water quality, materials must be allowed to cure at the correct temperature for the necessary length of time. This cannot always be achieved where materials are mixed on site, often in approximate proportions, and cured in situ often under cold, ill-ventilated conditions. Entries relating to products or products produced under properly controlled factory conditions, cannot be guaranteed to apply to site conditions.

Water Regulations Advisory Scheme
30 Park Close, First Floor Industrial Estate,
Osborne, Gosport, PO13 3JL, UK.
Tel: 01405 248554 Fax: 01405 249234
E-mail: info@wras.co.uk Website: www.wras.co.uk

WRAS 08
Approved Product 0311503
Approved Product 0311503
Approved Product 0311503